

Viral Filtration Efficiency (VFE) Final Report

Test Article: Standard Cambridge Mask w/ Carbon Filter
Laboratory Number: 823624
Study Received Date: 26 May 2015
Test Procedure(s): Standard Test Protocol (STP) Number: STP0007 Rev 11

Summary: The VFE test is performed to determine the filtration efficiency by comparing the upstream viral control counts to downstream test article counts. A suspension of bacteriophage ΦX174 was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and challenge delivery. The challenge delivery is maintained at $2,200 \pm 1,100$ plaque forming units (PFU) with a mean particle size (MPS) at $3.0 \mu\text{m} \pm 0.3 \mu\text{m}$. The aerosol droplets were drawn through a six-stage, viable particle, Andersen sampler for collection. This method allows a reproducible challenge to be delivered to the test articles. The VFE test procedure was adapted from ASTM F2101-07.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Inside
Area Tested: Entire Test Article
VFE Flow Rate: 28.3 Liters per minute (L/min)
Conditioning Parameters: $85 \pm 5\%$ relative humidity (RH) and $21 \pm 5^\circ\text{C}$ for a minimum of 4 hours.
Positive Control Average: 2,212 PFU
Negative Monitor Count: <1 PFU
MPS: $3.2 \mu\text{m}$

Results:

| Test Article Number | Percent VFE (%) |
|---------------------|-----------------|
| 1 | 99.8 |
| 2 | 99.6 |
| 3 | 99.3 |
| 4 | 99.7 |
| 5 | 99.7 |

The filtration efficiency percentages were calculated using the following equation:

$$\% VFE = \frac{C - T}{C} \times 100$$

C = Positive control average

T = Plate count total recovered downstream of the test article

Note: The plate count total is available upon request



Janelle R. Bentz
Study Director

Janelle R. Bentz, M.S.

09 Jun 2015
Study Completion Date